

ATTESTATION OF CONFORMITY

Issued to: Shenzhen SOFAR SOLAR Co., Ltd.
5/F, Building 4, Antongda Industrial Park, No.1 Liuxian Avenue, Xin'an Street,
Bao'an District, Shenzhen, P.R. China

For the product: Grid-connected PV Inverter



Trade name:

Type/Model: SOFAR 50000TL

Ratings: PV input: Max.1000 Vdc, MPPT voltage range: 250-950 Vdc, MPPT full power
voltage range: 530-800 Vdc, max 40/30/30 A, Isc PV: 48/36/36 A
Output: 400V, 3N~, 50 Hz, 50000 VA, max 3x80 A

Manufactured by: Shenzhen SOFAR SOLAR Co., Ltd.
5/F, Building 4, Antongda Industrial Park, No.1 Liuxian Avenue, Xin'an Street,
Bao'an District, Shenzhen, P.R. China

Requirements: EN 50530:2010+A1:2013

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in
test report no. 6041106.51

The examination has been carried out on one single specimen of the product, submitted by the
manufacturer.

The Attestation does not include an assessment of the manufacturer's production. Conformity of his
production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Shanghai, 2 November 2018

Number: 6041106.02AOC

DEKRA Testing and Certification (Shanghai) Ltd.


Kreny Lin
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed