



APPROVALS®

Certificate of Suitability

* Addendum *

Certificate No.: SAA180100

Date of Issue: 4 June 2020

Regulatory Definition: Non-Prescribed

Product Description: Solar Grid-tied Inverter

Additional Models	Trade Name	Rating/Marking
SOFAR 5KTLM-G2	SOFAR SOLAR	Input: 600Vdc Max, MPPT voltage range 90-580Vdc 2x11A IscPV 2x13.2A Output: 230V~ 50Hz 22.8A 5000VA IP65, Class I
SOFAR 4.6KTLM-G2	SOFAR SOLAR	Input: 600Vdc Max, MPPT voltage range 90-580Vdc 2x11A IscPV 2x13.2A Output: 230V~ 50Hz 21A 4600VA IP65, Class I
SOFAR 4KTLM-G2	SOFAR SOLAR	Input: 600Vdc Max, MPPT voltage range 90-580Vdc 2x11A IscPV 2x13.2A Output: 230V~ 50Hz 18.2A 4000VA IP65, Class I
SOFAR 3.6KTLM-G2	SOFAR SOLAR	Input: 600Vdc Max, MPPT voltage range 90-580Vdc 2x11A IscPV 2x13.2A Output: 230V~ 50Hz 16.8A 3680VA IP65, Class I
SOFAR 3KTLM-G2	SOFAR SOLAR	Input: 600Vdc Max, MPPT voltage range 90-580Vdc 2x11A IscPV 2x13.2A Output: 230V~ 50Hz 13.7A 3000VA IP65, Class I

R.A. Hill

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



Issued: 08-06-20 180100/2b
Correction to model numbers