

# Certificate of Conformity

Certificate Number: 190114153GZU-001

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. This certificate is part of the full test report<s> and should be read in conjunction with it ;

Applicant Name & Address:	Shenzhen SOFAR SOLAR Co., Ltd. 401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community, XinAn Street, BaoAn District, Shenzhen, China
Product Description:	Hybrid Inverter
Ratings & Principle Characteristics:	See Annex to Certificate of Conformity
Models:	HYD 3000-ES, HYD 3600-ES
Relevant Standards	G98 Issue 1 Amendment 3 March 2019 Requirements for the connection of Fully Type Tested Micro-generators (up to and including 16 A per phase) in parallel with public Low Voltage Distribution Networks
Certificate Issuing Office:	Intertek Testing Services Shenzhen Ltd. Guangzhou Branch Block E, No.7-2 Guang Dong Software Science Park, Caipin Road, Guangzhou Science City, GETDD, Guangzhou, China
Date of Tests:	14 Jan 2019 – 18 Mar 2019
Test Report Number(s):	190114153GZU-001

Additional information in Appendix.



## Signature

**Name:** Tommy Zhong  
**Position:** Technical Manager  
**Date:** 19 April 2019



This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Certificate are relevant only to the sample tested/inspected. This Certificate by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

## APPENDIX: Certificate of Conformity

This is an Annex to Certificate of Conformity with Certificate/Report Number(s): 190114153GZU-001; the issuing office is Intertek Legal Entity as above.

Ratings and  
principal  
characteristics

Max. DC Input Voltage: 600Vdc  
Operating MPPT Voltage Range: 90Vdc – 580Vdc  
Max. PV Isc: 2 X 15A  
Battery Type: Lead-acid, Lithium-ion  
Battery Voltage Range: 42-58V  
Max. Charging Current: 65A  
Max. Discharging Current: 70A  
Max. Charging & Discharging Power: 3000VA  
Nominal Grid voltage: 230Vac  
Nominal Output Voltage (backup): 230Vac  
Max. output current: 13.7A (for HYD 3000-ES), 16.0A (for HYD 3600-ES),  
Nominal Grid Frequency: 50Hz  
Power Factor: 1 (adjustable +/-0.8)  
Nominal output power: 3000VA (for HYD 3000-ES), 3680VA (for HYD 3600-ES)  
Backup Rated current: 13.2A  
Backup Rated Apparent Power: 3000VA  
Ingress Protection: IP 65  
Protective Class: I  
Operating temperature range: -25 — +60°C  
Software Version: V1.00

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Certificate are relevant only to the sample tested/inspected. This Certificate by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.