



A P P R O V A L S ®

Certificate of Suitability

Certificate No.: SAA183423

Certificate Holder: Shenzhen SOFARSOLAR Co., Ltd.
401, Building 4, AnTongDa Industrial Park,
District 68, XingDong Community,
XinAn Street, BaoAn District,
Shenzhen,
P.R. China

Regulatory Definition: Non-Prescribed
Product Description: Hybrid Inverter
Trade Name: SOFARSOLAR
Model No.: HYD 6000-ES
Rating/Marking: Input: 600Vdc Max, Isc PV 2x15A
Output: 230V~ 50/60Hz 27.3A 6000VA
Backup: 230V~ 50Hz 13.2A 3000VA
Battery: 42-58Vdc charge/discharge 65/70A
IP65, Class I

Standard: IEC 62109-1 Ed. 1.0
IEC 62109-2 Ed. 1.0
AS/NZS 4777.2:2015

Conditions: Nil

Certification Mark: RCM and SAA183423

Date First Registered: 10 December 2018

Date of Expiry: 10 December 2023

R.A. Hill

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



Issued: 10-06-20 183423/1a
Reissued under RECS Scheme

www.jas-anz.org/register