




Certificate of Conformity

Certificate No.: 2188AP020105024
Product: AC-Coupled Storage Inverter
Brand Name: 
Test Model No.: ME 5KTL-3PH, ME 6KTL-3PH, ME 8KTL-3PH,
ME 10KTL-3PH, ME 15KTL-3PH, ME 20KTL-3PH
Applicant: Shenzhen SOFARSOLAR Co., Ltd.
401, Building 4, AnTongDa Industrial Park, District 68, XingDong Community,
XinAn Street, BaoAn District, Shenzhen, China
Report No.: PVUK2102WDG0105-1

Use in accordance with regulations:

Automatic disconnection device with three-phases mains surveillance in accordance with Engineering Recommendation G99/1-6 for photovoltaic systems with a three-phases parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

Applied rules and standards

Engineering Recommendation G99/1-6:2020

For Type A inverter connected Power Generating Modules

Requirements for the connection of generation equipment in parallel with public distribution networks

DIN V VDE V 0126-1-1:2006-02 (Functional safety)

Automatic disconnection device between a generator and the public low-voltage grid



Name: James Huang
Technical Manager/ New Energy Team
Date: 2021-03-31

This document shall not be reproduced, except in full, without the written approval of
Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch.
Information given in this document is related to the tested specimen of the described electrical sample.